

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. 58/2025

Date: 17/02/25

It is certified that an inspection team headed by Dr. Shabda
Shirpurkar medical officer from Government
Health Department Khadakwasala Pune Maharashtra 411024 inspected the
Pawar Public School, Nanded City, Sinhagad Road, Pune, Maharashtra 411041 on
17/02/25 and found that the Pawar Public School has safe drinking water facilities
for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed by
the Central/State/U.T Govt.

The above valid for a period of 01 yr

Shabda
वैद्यकीय अधिकारी

प्राथमिक आरोग्य विभाग - खडकवासला

Signature with Seal: ता. हवेली, जि. पुणे

Name: Dr. Shabda Shirpurkar

Designation: medical officer

To
Pawar Public School,
Nanded City, Sinhagad Road,
Pune Maharashtra 411041

Anjali Gurjar
Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411041





**DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
Near St. Mary School And Church, Pune 411001**



Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com

HEALTH SERVICES

NO. SPHL PUNE /Desk -79 /202/ 2025. DATE :- 25/02/2025.

Report on Chemical Analysis of Drinking Water

Sent by :- Pawar Public School, Nanded City Sinhgad road, Pune.

With Ref. letter No : -----

Dated :- 11/ 02/2025

Date of Collection :- ----

Date of Receipt :- 11/02/2025

Date of Examination :- 12/ 02/ 2025 onwards

(All the Analytical Results are in mg. / Lit. except pH , Turbidity)

SR. NO	TEST PARAMETER	S.No. - 1 (P-166) Aqua Filter Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity (as N.T.U.)	1.14	1.0	5.0
4	pH Value	8.05	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	10.81	250	1000
6	Nitrates (as No3)	0.46	45	No relaxation
7	Total Hardness (as Caco3)	26.37	200	600
8	Alkalinity (as Caco3)	38.99	200	600
9	Total Dissolved Solids	58.0	500	2000
10	Iron (as Fe)	ND	1.0	No relaxation
11	Fluoride (as F)	ND	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

Remark:- Water Sample.1 Contains Turbidity more than desirable limit 1.0 N.T.U. resp as per BIS Specifications 10500 : 2012.

However, if there is no any other alternate source available near by then this water source can be used for drinking purpose only after proper treatment , disinfection & ascertaining it's bacteriological quality frequently or regularly.

**Forwarded With Compliments To :- Pawar Public School, Nanded City
Sinhgad road, Pune.**

Fees	600 /-
Receipt No.	5118951
Date	11/02/2025



Dr. Anjali Gurjar
Dr. Anjali Gurjar
Principal

**PAWAR PUBLIC SCHOOL NANDED CITY
Sinhgad Road, Pune 411041**

Chakwa
Senior Scientific Officer
State Public Health Laboratory
Pune-411 001

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411041